

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 03

Dated: 26/04/2024

It is certified that an inspection team headed by Ms. Anjali (Name of Officers with designation) from U.P. Jal Nigam (Rural), HATHRAS, inspected the **S.C.S.B. International School, Garh Tasinga Sadabad Hathras** (Name & Address of the school) on **22/04/2024** (date of inspection) and on the basis of Water Test Report(Attached) bearing no **UPJN/HAT/24/04/03** dated **26/04/2024** of **District Level Water Analysis Laboratory (UP JAL NIGAM)** certified that the **S.C.S.B. INTERNATIONAL SCHOOL**(Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 6 months from issue date

Signature with Seal

Name:

Designation:

Name & Address of the Office / Department :



To

**S.C.S.B. INTERNATIONAL SCHOOL,
GARH TASINGA SADABAD
HATHRAS**



Test Report

District Level Water Analysis Laboratory

Address: Raya road, Sadabad, U.P. Jal Nigam, Hathras, 281306

Report No:	UPJN/HAT/24/04/03	Issue Date:	26/04/2024		
Customer Details					
Office Name and Address	S.C.S.B International School, Sadabad				
Ref Letter No & Date	NA				
Basic details of sample					
District	Hathras	Block	Sadabad		
Gram Panchayat	Tasinga	Village	Garh		
Habitation	-	Location	Mathura Road		
Water Source	RO water	Sample No.	01		
Quantity of Sample	1 Liter	Date of Collection	22/04/2024		
Receiving Date	22/04/2024	S.Collector	Amit kumar		
Sample Depositor	Amit kumar	Sampling Method	NA	Environment condition	25±3°C
Analysis Start Date	23/04/2024	Analysis Completion Date:	24/04/2024		
Technical Data of Analysis					
	Analyzed parameters (Unit of Measurement)	Observed Value	Specified Values as per BIS		Ref. Method of Analysis
			Acceptable Limit	Permissible Limit	
1	2	3	4	5	6
1	pH	7.01	6.5-8.5	6.5-8.5	IS3025(Part11):2022(Electrometric method)
2	Turbidity(NTU)	0.00	1	5	IS3025(Pt10):2023(Nephelometric method)
3	TDS(mg/L)	222	500	2000	IS3025(Pt16):2023(Gravimetric method)
4	Fluoride(mg/L)	0.01	1	1.5	APHA24rthEdition4500-FMethodC (Electrode method) 2023
5	Total Hardness (mg/L)	65	200	600	IS3025(Part21):2009(EDTA Method)
6	Total Alkalinity (mg/L)	35	200	600	IS3025(Part23):2023(Potentiometricand indicator method)
7	Chloride(mg/L)	97.5	250	1000	IS3025(Part32):1988 (Argent metric method)

8	Iron(mg/L)	0.09	1	No relaxation	APHA24rthEdition3500-FeMethodB (Phenanthroline Method) 2023
9	Sulphate (mg/L)	23.03	200	400	APHA24rth Edition4500-SO4MethodE (Turbidity Method) 2023
10	Calcium(mg/L)	10.02	75	200	IS3025(Part40):1991(EDTA Titrimetric Method)
11	Magnesium (mg/L)	9.72	30	100	IS3025(Part46):1994(volumetric Method)
12	Color(Hazen)	BDL	5	15	IS3025(part4)2021(Visual Comparison Method)
13	Taste	Agreeable	Qualitative	-	IS3025(part8)2023 (Qualitative Method)
14	Odour	Agreeable	Qualitative	-	IS3025(Part05)2018(qualitative Method)
15	Nitrate	4.18	45	No relaxation	APHA24rth Edition-4500-No3MethodB 2023

Note

- 1 .This Certificate refers only to the particular sample(s) submitted for testing.
- 2 .This certificates shall not be reproduced, excepting full, unless written permission for the publication of an approved abstract.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Sample will be stored upto7days (in case of non-perishable items only) from the date of issue of tests reports.
- 5.BDL- Below Detection Limit



END OF REPORT